

**FIRE & EMERGENCY SERVICES**

(MUNICIPAL CORPORATION, CHANDIGARH)

**APPLICATION/PERFORMA FOR OBTAINING/RENEWAL OF FIRE SAFETY NOC FOR RESIDENTIAL BUILDINGS (HOTELS) LESS THAN 15 METER IN HEIGHT AND FLOOR AREA EXCEEDING 300 m<sup>2</sup> BUT NOT MORE THAN 1000 m<sup>2</sup> ON ANY OF THE FLOOR.**

Application Date-\_\_\_/\_\_\_/20\_\_

<b>DETAIL OF BUILDING/PREMISES</b>				
01.	Name of building premises (Location and Address)			
02.	Name, Address and Contact No. of Building Owner			
03.	Name, Address and Contact No. of Applicant			
04.	No. of inhabitants/occupants			
05.	Plot Area (in Sq. Meters)			
06.	Total covered area (in Sq. Meters)			
07.	Over all Height (From Ground Level to Parapet) in Meters			
08.	Height upto terrace of last livable floor (in Meters).			
09.	Height of each floor (in Meters)			
10.	Number of sanctioned floors			
11.	Number of actual floors			
12.	Number of staircase with size			
13.	Please indicate floors to whom NOC is required			
14.	Motorable space provided all around the building			
15.	Number of Basement and its area			
16.	Detail of Means of escape			
17.	Detail of Parking area			
18.	Details of surrounding properties:- a) Front side b) Rear side c) Right side d) Left side			
19.	Number of entry and exit gates with size			
20.	Location of Gen-set with size			
<b>MANDATORY FIRE SAFETY MEASURES AS PER NATIONAL BUILDING CODE OF INDIA-2016</b>				
<b>A) FIRE FIGHTING EQUIPMENTS</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Fire Extinguishers ISI Mark			
02.	First Aid Hose Reel			
03.	Wet Riser System [Required to be provided for building with more than two storey's (Ground + One)]			
04.	Automatic Sprinkler System required to be installed in Basement (if area of Basement exceeds 200 m <sup>2</sup> ) especially extended throw, quick response type sprinklers for guest rooms and suites.			
05.	Terrace Tank over respective tower terrace capacity 10000 Liter exclusively for Fire-fighting purpose alongwith Pump capacity 450 LPM at the terrace tank level with minimum pressure of 3.5 Kg/cm <sup>2</sup>			

06.	An additional Terrace Tank over respective tower terrace capacity 5000 Liter exclusively for Fire-fighting purpose alongwith Pump capacity 450 LPM at the terrace tank level with minimum pressure of 3.5 Kg/cm <sup>2</sup> (if basement area exceed 200m <sup>2</sup> )			
07.	Underground Static Water Storage Tank capacity 10,000 Liter exclusively for Fire-fighting purpose for every 500m <sup>2</sup> floor area subject to minimum of 50000 liter [Required to be provided for building with more than two storey's (Ground + One)]			
08.	Provision of required number of sets of pumps each consisting of One Electric and One Diesel Pump (Standby) of capacity 1620 Liter Per Minute and One Electric Pump of capacity 180 Liter Per Minute for each 100 hydrants or part thereof, with a maximum of two sets. In case, more than one pumps set installation, both the pump sets should be interconnected at their delivery header. Alternate to this additional diesel pump of same capacity and doubling the water tank capacity as required for one set of pump may be provided.			
09.	Four-Way Fire Brigade Connection with NRV in Box			
<b>B) DETECTION AND ALARAM SYSTEM</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Manually Operated Electronic Fire Alarm System			
02.	Automatic Detection and Alarm System			
03.	Provision of Audio Based Detectors, having a sound level of at least 75 dB for guest rooms and suites			
<b>C) EVACUATION PROVISIONS</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Provision of Panic Bar at Fire Exit			
02.	Prohibition of Horizontal sliding doors for door opening across corridors.			
03.	Provision of Illuminated type EXIT Signboards at all escape routes			
<b>D) FIRE PREVENTION MEASURES</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Provision of tightly stoppered/ sealed containers for flammable liquids.			
02.	Prohibition of location of Stove/heater near or Underneath Staircase or other escape route.			
03.	Proper provision of Smoke Exhaust Ducting (made with non-combustible material) with adequate protection.			
04.	Provision of minimum 120 minutes Fire Resistance Rated Wall along with Fire Doors to be kept closed and shall be posted with a sign on each side of the door stating-----FIREDOOR-----KEEP CLOSED for stores, Engineering Workshops, Area of High Hazard etc.			

**DOCUMENTS TO BE ATTACHED**

<b>01.</b>	Approved Fire Safety Layout Plan	<b>YES</b>	<b>NO</b>	
**The inspecting officer may also suggest further requirements as deemed necessary in Public Interest at the time of inspection.				

(SIGNATURE OF THE APPLICANT)

**Recommendations of the Inspection Officer**

**Note:** - the inspection officer should mention the deficiencies found during the inspection and copy of the report to be issued to the owner/occupier.

	<b>Signature</b> _____ <b>Name of inspecting officer</b> _____ <b>Designation</b> _____ <b>Date of Inspection</b> _____ <b>Contact No.</b> _____
--	--

**RECEIPT**

<b>Name of the Recipient</b> _____	<b>Contact No.</b> _____
<b>Signature</b> _____	<b>E-Mail ID</b> _____
<b>Date of receipt</b> ___ / ___ / ___	