

FIRE & EMERGENCY SERVICES
(MUNICIPAL CORPORATION, CHANDIGARH)

APPLICATION/PERFORMA FOR OBTAINING/RENEWAL OF FIRE SAFETY NOC FOR BUSINESS BUILDINGS ABOVE 24 METER AND UP TO 30 METER IN HEIGHT.

Application Date- ___ / ___ /20___

DETAIL OF BUILDING/PREMISES				
01.	Name of Building Premises (Location and Address)			
02.	Name, Address and Contact No. of Building Owner			
03.	Name, Address and Contact No. of Applicant			
04.	No. of inhabitants/occupants			
05.	Plot Area (in Sq. Meters)			
06.	Total covered area (in Sq. Meters)			
07.	Over all Height (From Ground Level to Parapet) in Meters			
08.	Height upto terrace of last livable floor (in Meters).			
09.	Height of each floor (in Meters)			
10.	Number of sanctioned floors			
11.	Number of actual floors			
12.	Number of staircase with size			
13.	Please indicate floors to whom NOC is required			
14.	Motorable space provided all around the building			
15.	Number of Basement and its area			
16.	Detail of Means of escape			
17.	Detail of Parking area			
18.	Details of surrounding properties:- a) Front side b) Rear side c) Right side d) Left side			
19.	Number of entry and exit gates with size			
20.	Location of Gen-set with size			
MANDATORY FIRE SAFETY MEASURES AS PER NATIONAL BUILDING CODE OF INDIA-2016				
A) FIRE FIGHTING EQUIPMENTS		YES	NO	Remarks of Inspection Authority Ok or not
01.	Fire Extinguishers ISI Mark			
02.	First Aid Hose Reel			
03.	Wet Riser System with Accessories in Box			
04.	Yard Hydrants with Accessory in Box			
05.	Automatic Sprinkler System			
06.	Terrace Tank over respective tower terrace capacity 20000 Liter exclusively for Fire-fighting purpose			
07.	Underground Static Water Storage Tank capacity 150000 liter exclusively for Fire-fighting purpose.			
08.	Provision of required number of sets of pumps each consisting of Two Electric and One Diesel Pump (Standby) of capacity 2280 Liter Per Minute and Two Electric Pump of capacity 180 Liter Per Minute for each 100 hydrants or part thereof, with a maximum of two sets. In case, more than one pumps set installation, both the pump sets should be			

	interconnected at their delivery header. Alternate to this additional diesel pump of same capacity and doubling the water tank capacity as required for one set of pump may be provided.			
09.	Four-way Fire brigade connection with NRV in Box			
B) DETECTION AND ALARAM SYSTEM		YES	NO	Remarks of inspection Authority Ok or not
01.	Manually Operated Electronic Fire Alarm System			
02.	Provision of Automatic Detection and Alarm System and CO2/foam based installation based on the requirements [for E-2 occupancies i.e. Laboratories, outpatient clinic, research establishments, libraries and test houses etc.]			
03.	Provision of Automatic Detection and Alarm System and Clean Agent/Mist Technology/Hypoxic Air Technology based installation for appropriate locations [for E-3, E-4 & E-5 occupancies i.e. Electronic Data Processing Centers, Computer Installations, IT Parks, Call Centers, Telephone Exchanges, Broadcasting Stations, T.V. Stations, Air Traffic Control Towers etc]			
04.	Smoke Exhauster System in Basement Connected to Detection/Sprinkler System			
05.	Gong Bell connected with Sprinkler System.			
06.	Public Address System			
07.	Pressurization System in Internal Staircase, Lift Lobby & Fire Lift connected with Detection/Sprinkler System.			
08.	Provision of Fire Dampers in AHU/AC Ducts			
C) EVACUATION PROVISIONS			NO	Remarks of Inspection Authority Ok or not
01.	Provision of at least 02 Exits at every floor.			
02.	Provision of one Fire-fighting shaft necessarily have connectivity directly to EXIT discharge /Passageway having 120 minutes Fire Resistance wall to Exit discharge.			
03.	Fire Check Doors.			
04.	Fire Lift with Fireman Switch			
05.	Fire Command Centre at Ground Floor with Accessories			
06.	Provision of Illuminated Type EXIT Signboards at all escape routes			
07.	Alternative Source of Electricity Supply			
08.	Emergency Lights in Staircase			
09.	Provision of Refuge Area as per NBC norms for building more than 24 meter in height immediately above 24 meter and thereafter at every 15 meter or so			
D) FIRE PREVENTION MEASURES				
01.	Minimum 06 meter wide Motorable Road/Passage all around the Building			

02.	Provision of CO ² /Inert Gas Flooding System in Electrical Panels based on the requirement and reliability of the power for functional requirement and performance [for E-3, E-4 & E-5 occupancies i.e. Electronic Data Processing Centers, Computer Installations, IT Parks, Call Centers, Telephone Exchanges, Broadcasting Stations, T.V. Stations, Air Traffic Control Towers etc]			
-----	---	--	--	--

DOCUMENTS TO BE ATTACHED

1.	Approved Fire Safety Layout Plan	YES	NO
----	----------------------------------	-----	----

**The inspecting officer may also suggest further requirements as deemed necessary in Public Interest at the time of inspection.

(SIGNATURE OF THE APPLICANT)

Recommendations of the Inspection Officer

Note: - the inspection officer should mention the deficiencies found during the inspection and a copy of the report to be issued to the owner/occupier.

	Signature _____ Name of inspecting officer _____ Designation _____ Date of Inspection _____ Contact No. _____
--	--

RECEIPT

Name of the Recipient _____ Signature _____ Date of receipt ___ / ___ / ___	Contact No. _____ E-Mail ID _____
--	--