

FIRE & EMERGENCY SERVICES

(MUNICIPAL CORPORATION, CHANDIGARH)

APPLICATION/PERFORMA FOR OBTAINING/RENEWAL OF FIRE SAFETY NOC FOR INDUSTRIAL BUILDINGS [MODERATE HAZARD] COVERED AREA MORE THAN 500 m² AND UP TO 1000 m² {FOR BUILDING HEIGHT UP TO 15 METER}

Application Date- ___/___/20__

DETAIL OF BUILDING/PREMISES				
01.	Name of building premises (Location and Address)			
02.	Name, Address and Contact No. of Building Owner			
03.	Name, Address and Contact No. of Applicant			
04.	No. of inhabitants/occupants			
05.	Plot Area (in Sq. Meters)			
06.	Total covered area (in Sq. Meters)			
07.	Over all Height (From Ground Level to Parapet) in Meters			
08.	Height upto terrace of last livable floor (in Meters).			
09.	Height of each floor (in Meters)			
10.	Number of sanctioned floors			
11.	Number of actual floors			
12.	Number of staircase with size			
13.	Please indicate floors to whom NOC is required			
14.	Motorable space provided all around the building			
15.	Number of Basement and its area			
16.	Detail of Means of escape			
17.	Detail of Parking area			
18.	Details of surrounding properties:- <div style="margin-left: 20px;"> a) Front side b) Rear side c) Right side d) Left side </div>			
19.	Number of entry and exit gates with size			
20.	Location of Gen-set with size			
MANDATORY FIRE SAFETY MEASURES AS PER NATIONAL BUILDING CODE OF INDIA-2016				
A) FIRE FIGHTING EQUIPMENTS		YES	NO	Remarks of Inspection Authority Ok or not
01.	Fire Extinguishers ISI Mark			
02.	First Aid Hose Reel			
03.	Down Comer System with Accessories in Box			
04.	Automatic Sprinkler System			
05.	Terrace Tank over respective tower terrace capacity 50000 Liter exclusively for Fire-fighting purpose alongwith Pump capacity 900 LPM at the terrace tank level with minimum pressure of 3.5 Kg/cm ²			

06.	Two-Way Fire Brigade Connection with NRV in Box			
B) DETECTION AND ALARM SYSTEM				
01.	Manually Operated Electronic Fire Alarm System			
02.	Automatic Detection and Alarm System			
C) EVACUATION PROVISIONS		YES	NO	Remarks of Inspection Authority Ok or not
01.	Provision of Exit for the person actually employed			
02.	Provision of Illuminated Type EXIT Signboards at all escape routes			
D) FIRE PREVENTION MEASURES				Remarks of Inspection Authority Ok or not
01.	Provision of Fire Separation between hazardous and non-hazardous Area by means of Fire Rated Wall/doors of minimum 120 minute Fire Resistance Rating for normal hazard and 240 minute for high hazard			
02.	Prohibition on Flame Generating Devices in the area of storage of volatile flammable substances			
03.	Provision of Exhaust Ventilation System			
04.	Sealing of Various Shafts/Ducts at each floor Level with Fire Resistant Material			
DOCUMENTS TO BE ATTACHED				
01.	Approved Fire Safety Layout Plan	YES	NO	
**The inspecting officer may also suggest further requirements as deemed necessary in Public Interest at the time of inspection.				

(SIGNATURE OF THE APPLICANT)

Recommendations of the Inspection Officer	
Note: - the inspection officer should mention the deficiencies found during the inspection and copy of the report to be issued to the owner/occupier.	
	Signature _____ Name of inspecting officer _____ Designation _____ Date of Inspection _____ Contact No. _____
RECEIPT	
Name of the Recipient _____	
Signature _____	Contact No. _____
Date of receipt ___ / ___ / ___	E-Mail ID _____