

## **FIRE & EMERGENCY SERVICES**

(MUNICIPAL CORPORATION, CHANDIGARH)

### **APPLICATION/PERFORMA FOR OBTAINING/RENEWAL OF FIRE SAFETY NOC FOR INDUSTRIAL BUILDINGS [HIGH HAZARD] COVERED MORE THAN 500 m<sup>2</sup>.**

Application Date- \_\_\_ / \_\_\_ /20\_\_\_

<b>DETAIL OF BUILDING/PREMISES</b>				
01.	Name of building premises (Location and Address)			
02.	Name, Address and Contact No. of Building Owner			
03.	Name, Address and Contact No. of Applicant			
04.	No. of inhabitants/occupants			
05.	Plot Area (in Sq. Meters)			
06.	Total covered area (in Sq. Meters)			
07.	Over all Height (From Ground Level to Parapet) in Meters			
08.	Height upto terrace of last livable floor (in Meters).			
09.	Height of each floor (in Meters)			
10.	Number of sanctioned floors			
11.	Number of actual floors			
12.	Number of staircase with size			
13.	Please indicate floors to whom NOC is required			
14.	Motorable space provided all around the building			
15.	Number of Basement and its area			
16.	Detail of Means of escape			
17.	Detail of Parking area			
18.	Details of surrounding properties:- a) Front side b) Rear side c) Right side d) Left side			
19.	Number of entry and exit gates with size			
20.	Location of Gen-set with size			
<b>MANDATORY FIRE SAFETY MEASURES AS PER NATIONAL BUILDING CODE OF INDIA-2016</b>				
<b>A) FIRE FIGHTING EQUIPMENTS</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Fire Extinguishers ISI Mark			
02.	First Aid Hose Reel			
03.	Wet Riser System with Accessories in Box			
04.	Automatic Sprinkler System			
05.	Yard Hydrants with Accessories in Box			
06.	Terrace Tank over respective tower terrace capacity 20000 Liter exclusively for Fire-fighting purpose			
07.	Underground static Water Storage Tank capacity 150000 Liter exclusively for Fire-fighting purpose			
08.	Provision of required number of sets of pumps each consisting of Two Electric and One Diesel Pump (Standby) of capacity 2280 Liter Per Minute and Two Electric Pump of capacity 180 Liter Per Minute for each 100 hydrants or part thereof, with a maximum of two sets.			

	In case, more than one pumps set installation, both the pump sets should be interconnected at their delivery header. Alternate to this additional diesel pump of same capacity and doubling the water tank capacity as required for one set of pump may be provided.			
09.	Four-Way Fire Brigade Connection with NRV in Box			
<b>B) DETECTION AND ALARM SYSTEM</b>				
01.	Manually Operated Electronic Fire Alarm System			
02.	Automatic Detection and Alarm System			
<b>C) EVACUATION PROVISIONS</b>		<b>YES</b>	<b>NO</b>	<b>Remarks of Inspection Authority Ok or not</b>
01.	Provision of Exit for the person actually employed			
02.	Provision of Illuminated Type EXIT Signboards at all escape routes			
<b>D) FIRE PREVENTION MEASURES</b>				
<b>Remarks of Inspection Authority Ok or not</b>				
01.	Prohibition on Flame Generating Devices in the area of storage of volatile flammable substances			
02.	Provision of Exhaust Ventilation System			
03.	Sealing of Various Shafts/Ducts at each floor Level with Fire Resistant Material			
<b>DOCUMENTS TO BE ATTACHED</b>				
01.	Approved Fire Safety Layout Plan	<b>YES</b>	<b>NO</b>	
**The inspecting officer may also suggest further requirements as deemed necessary in Public Interest at the time of inspection.				

(SIGNATURE OF THE APPLICANT)

<b>Recommendations of the Inspection Officer</b>	
<b>Note:</b> - the inspection officer should mention the deficiencies found during the inspection and copy of the report to be issued to the owner/occupier.	
	<b>Signature</b> _____ <b>Name of inspecting officer</b> _____ <b>Designation</b> _____ <b>Date of Inspection</b> _____ <b>Contact No.</b> _____
<b>RECEIPT</b>	
Name of the Recipient _____	
Signature _____	Contact No. _____
Date of receipt ___ / ___ / _____	E-Mail ID _____